

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications

BOOM Concrete, Inc.

Specifications for BOOM Clovermist Precast Concrete Vault Toilet

1.0 SCOPE

- 1.1 This specification covers the prefabrication, on-site delivery, off loading and placement of the Clovermist precast concrete vault restrooms as produced by BOOM Concrete, Inc.

2.0 SPECIFICATIONS

- 2.1 ASTM C33 - Concrete Aggregates
- 2.2 ASTM C39 - Method of Test for Compressive Strength of Cylindrical Concrete Specimens
- 2.3 ASTM C143 - Method of Test for Slump of Concrete
- 2.4 ASTM C150 - Standard Specification for Portland Cement
- 2.5 ASTM C192 - Method of Making and Curing Test Specimens in the Laboratory
- 2.6 ACI 1211.1 - Recommended Practices for Selecting Proportions for Normal and Heavyweight Concrete
- 2.7 ASTM A615 - Reinforcing Steel
- 2.8 ASTM A185 - Welded Wire Mesh
- 2.9 PCIMNL 116 - Quality control for Plants and Production of Precast Pre-stressed Concrete Products

3.0 DESIGN CRITERIA

- 3.1 Vault restrooms have been designed to meet the following criteria. Calculations and Engineer's stamped drawings are available upon request by the customer and are for their sole and specific use only. The design criteria are to ensure that vault restrooms not only will withstand the forces of nature listed below but to provide protection from vandalism and other unforeseen hazards.
- 3.2 Snow Load: The vault restroom will withstand a snow load of 350 pounds per square foot.
- 3.3 Wind Load: The vault restroom will withstand the effects of 150 mile per hour wind load (3 second-gust), Exposure C.
- 3.4 Seismic Zone: The vault restroom will withstand the effects of group 1, category E.
- 3.5 Floor Load: The vault restroom floor will withstand loads of 400 pounds per square foot.
- 3.6 The vault restroom is designed to meet the requirements of the Americans with Disabilities Act Requirements and Uniform Federal Accessibility Standard including as of the date of these specifications.
- 3.7 The vault restroom shall have full 60" turning diameter in each interior and entry area.
- 3.8 The vault restroom incorporates all design aspects of Sweet Smelling Technology as outlined by Brian Cook for the U. S. Forest Service. ("In Depth Design and Maintenance Manual for Vault Toilets" - July - 1991 - Publication No. 9123 1601). All BOOM Clovermist toilets have an improved design with a solar heat chamber built into the 7:12 pitch roof which eliminates all odor associated with out-door toilets.
- 3.9 Tolerances: Tolerances will be within the limits as dictated by the PCI Quality Control and Assurance Manual.

4.0 MATERIALS

- 4.1 Concrete mix design, mixing and delivery, placement finishing, curing and quality assurance.
 - 4.1.1 Concrete will contain proper proportion of cement, aggregate, and water to obtain concrete with good workability. Minimum strength concrete: 5,000 PSI at 28 days.
 - 4.1.2 Cement will be ASTM C-150 Type II SR (Sulfur resistant) or Type V, 6.5 sacks per cubic yard.
 - 4.1.3 ASTM C33 with designated size of coarse aggregate No. 67 (3/4" to No. 4).
 - 4.1.4 Potable water with minimum water/cement ratio 5.0 gallons per sack.
 - 4.1.5 Slump will be 3" to 5" by ASTM C231.
 - 4.1.6 Air content shall be 4 to 7 percent as per ASTM C231. Air-entrained admixtures will conform to ASTM C260. Water reducing admixtures will conform to ASTM C494, Type A. Use of other admixtures is subject to approval.



BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications



- 4.1.7 Curing compound will be colorless complying with ASTM C309, Type I or I-D
- 4.2 Colored Concrete – Color requirements for pre-cast toilets.
- 4.2.1 The toilet building roof, wall panels to floor line and screen panels will be precast with integrally colored concrete where appropriate.
- 4.2.2 The same type and brand of cement, color, aggregates, and other additives shall be used throughout. In addition, as far as is reasonably practicable, all ingredients shall be from the same lot or manufacturing process. Aggregates shall be from the same source.
- 4.2.3 All volumes of concrete shall be uniform in all respects to ensure uniformity of the color of the finished concrete. All ingredients shall be weighed. All color by weight as recommended by the manufacturer of the concrete color. The mixing operations shall be adequate to uniformly disperse the color throughout each batch. A 12"x12"x1" color sample will be available for customer approval.
- 4.2.4 Wash and thoroughly clean the mixer and transporting equipment before mixing colored concrete.
- 4.2.5 Color additive shall be the color specified on the delivery order. Standard schedule of colors will be available from manufacturer.
- 4.3 Cold/Hot Weather Concrete
- 4.3.1 Cold weather concrete placement shall be in accordance with ACI 306.
- 4.3.2 Concrete will not be placed if ambient temperature is expected to be below 30° Fahrenheit during the curing period unless heat is readily available to maintain the surface temperature of the concrete at least 45° Fahrenheit.
- 4.3.3 Materials containing frost or lumps of frozen materials will not be used.
- 4.3.4 Hot Weather Concrete: The temperature of the concrete will not exceed 80° Fahrenheit. At the time of placement and when the ambient temperature reaches 90° Fahrenheit. The concrete will be protected with moist covering.
- 4.4 Concrete Reinforcement
- 4.4.1 All reinforcing steel will conform to ASTM A615. All welded wire fabric will conform to ASTM A185.
- 4.4.2 All reinforcement will be new, free of dirt, oil, paint, grease, mill scale, loose or rust when placed. Reinforcement will be stored on blocks or saw horse off the ground in a manner to prevent bending, rusting and accumulation of dirt or soil.
- 4.4.3 Reinforcement will be installed as shown on the drawings and if details of reinforcement are not shown will be in accordance with ACI 318.
- 4.4.4 Steel reinforcement will be centered in the cross-sectional area of the concrete member unless otherwise specified on the drawings.
- 4.4.5 Welded wire mesh in flat sheet form may be substituted in place of reinforcing steel in the roof slab and the exterior slab. The steel area of the wire mesh must be equal to or greater than the steel bar area. No more than two layers of welded mesh will be allowed in any concrete section to provide the required steel area. Mesh openings for two layers of mesh shall be shifted ½ mesh grid size both ways.
- 4.4.6 Adequate placement and support of reinforcing steel and wire mesh in final position will occur before starting placement of concrete.
- 4.4.7 Reinforcing steel will be continuous around corners between adjacent walls. Full lengths of reinforcing steel will be used whenever possible and the number of splices will be kept to a minimum. On long runs, splices will be alternated from opposite sides of the component for adjacent steel bars.
- 4.5 Concrete Sealers
- 4.5.1 Clear, colorless polysiloxane resin penetrating sealer for weatherproofing concrete which meets performance requirements of Federal Specification SS-W-110b
- 4.5.2 Weatherproofing sealer for exterior of building will be transparent, non-yellowing methyl methacrylate acrylic resin sealer, minimum 20% solids, for weatherproofing concrete exteriors. Low luster finish.

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications



4.6 Caulking, Grout, Adhesive and Sealer

- 4.6.1 In accordance with Federal Specifications TTS-01543A, BASF Sonolastic NP 1 Polyurethane Sealant or equal will be used with standard colors of white for inside surfaces and color to match the exterior.
- 4.6.2 Epoxy concrete adhesive will be two components rigid, non sag gel adhesive for bonding to dry or damp surfaces, moisture insensitive. Gray or other approved color.
- 4.6.3 Portland cement mortar will consist of one part Portland cement, three parts sand and enough water to make a workable mixture.

4.7 Paint

- 4.7.1 All paints and materials will conform to all Federal specifications or be similar "top-of-the-line components". Paints will be lead free. Standard paint materials and finish will be as follows:
 - 4.7.2 Metalwork, steel doors
 - 4.7.2.1 Factory Primed
 - 4.7.2.1.1 Metalwork and steel doors will be primed with a one coat zinc dust metal primer, Federal Specification TT-P-1046A. Primer not required on items delivered shop primed.
 - 4.7.2.1.2 A minimum of one coat semi-gloss alkyd exterior enamel as per Federal Specification TT-509 Class A will be applied to all metalwork. The color of enamel will be dark brown, Federal Standard#595A
 - 4.7.2.2 Factory Powdercoat
 - 4.7.2.2.1 Metalwork and steel doors will be powder coated by the manufacturer using Sherwin Williams 410 Teakwood brown finish.
- 4.7.3 The interior walls will be painted using a two part, high gloss polyamide epoxy enamel, white in color with a minimum of one primer coat and one color coat; or 2 coats of a modified acrylic, water repellent penetrating stain.
- 4.7.4 Interior floors will be a one or two part, high gloss polyamide epoxy enamel, tan or grey in color. There will be a minimum of one primer coat and one color coat.
- 4.7.5 Exterior concrete surfaces.
 - 4.7.5.1 Exposed Aggregate surfaces will be sprayed with a clear, water based penetrating sealer with water repellent and graffiti resistant properties.
 - 4.7.5.2 Barnwood surfaces will be sprayed with 2 coats of water repellent penetrating stain in the same color as the walls followed by one coat of anti-graffiti sealer.
 - 4.7.5.3 Colonial Dry Stack may be left untreated to give weathered rock finish.
 - 4.7.5.4 Cedar shake textured roof units will be sprayed with two coats of dark brown water repellent penetrating stain. Upper surface of roof units will be a dark color to aide positive airflow through the solar heat chamber in roof.
 - 4.7.5.1 Exterior slabs will be 1 coat of clear sealer.

4.8 Toilet Riser

- 4.8.1 Toilet Riser for the vault toilet will be 18" high, white cross linked polyethylene, with heavy duty seat and lid, as manufactured by Romtec, Roseburg, OR. The color will be white with safety bars consisting of one 3/4" stainless steel bars centered in the riser.

4.9 Grab bars

- 4.9.1 Stainless steel, 18 ga. material, satin non-slip finish, 1 1/2" outside diameter tubing, mounted with 1 1/2" wall clearance for handicapped, with concealed screw mounting flanges as manufactured by Tubular Specialties Manufacturing, 1-800-225-5876.

4.10 Toilet Paper Dispenser

- 4.10.1 Bar-type toilet paper dispenser shall be constructed of stainless steel with satin finish, designed to hold three standard rolls of toilet paper. All corners will be rounded and the holder will consist of two mounting brackets (predrilled and slotted) and one lockable bar.

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications



- 4.11 Signs
 - 4.11.1 With each order, Boom Concrete, Inc. shall be notified as to the number of toilet signs - MEN'S, WOMEN'S OR UNISEX.
 - 4.11.2 Appropriate signage will be installed to meet ADA-ABAAG standards. The required signs shall be mounted on the exterior wall of the toilet building adjacent to the latch side of the door. Signs will be attached and trimmed using a color matched Polyurethane Sealant.
 - 4.11.3 Signs will be 6"x 9" made of clear Lexan polycarbonate plastic with standard white recreation symbols or text on a brown background.
 - 4.11.4 Message "RESTROOM" will be in raised Grade 2 Braille across the bottom of the sign.
 - 4.11.5 As an option an interior sign reading "PLEASE DO NOT PUT TRASH IN TOILETS. IT IS EXTREMELY DIFFICULT TO REMOVE - Thank you" may be installed above each toilet riser.
- 4.12 Windows
 - 4.12.1 Glazing
 - 4.12.1.1 The standard toilet will be furnished with a 20"x36" window with 1/4" Lexan polycarbonate pebble finished glazing clear/opaque in color. Other optional sizes will be available.
 - 4.12.2 Steel Frame
 - 4.12.2.1 The window frame will be 16 ga. metal frame suitable for casting or installation in concrete wall. The frame wall thickness will be plus or minus 1/4". One coat of baked on primer coating will be factory applied or factory powdercoated using Sherwin Williams #410 Teakwood finish.
- 4.13 Steel Doors
 - 4.13.1 Steel Door - A 3'-0"x 6'-8" steel flush door will be installed in each toilet. It will be 1 3/4" thick, 18 gauge steel panels, 16 gauge internal bracing channels and 14 gauge hinge & lock rail of one piece construction. One coat of baked on primer coating will be factory applied or factory powdercoated using Sherwin Williams #410 Teakwood finish. Doors will be Lockseam LS-series by Shanahan's Manufacturing Ltd. 1-800-661-8420.
 - 4.13.2 Steel Door Frame will be welded type, single rabbet, that is a minimum 16 gauge steel, suitable for installation in precast concrete. Three rubber door silencers will be installed on the latch side of the door frame. Door frame will be factory primed with one coat of baked on coating or factory powdercoated using Sherwin Williams #410 Teakwood finish. Frames will be FW- series by Shanahan's Manufacturing Ltd. 1-800-661-8420.
 - 4.13.3 Spring Door Hinges will be 1-1/2 pair wrought steel, 4 1/2" x 4 1/2", adjustable tension, anti-friction bearing, non removable pin, automatic closing, in a satin brass finish. Hinges will be #1250 by Hager Companies, 1-800-255-3590.
 - 4.3.4 Chain door check will be available as an option to control door swing under windy conditions. Chrome plated zinc alloy base with welded galvanized steel chain attached with #8 self tapping screws. Tear resistant grey EDPM rubber UV protection cover with a 440 pound load strength. Door check # 300D by Hager Companies.
 - 4.13.4 Lockset
 - 4.13.4.1 Commercial grade, heavy-duty cylindrical lockset for exterior door. UL listed complies with ASNI A156.2, series 4000, grade 1, function F76-1 and meets ADA-ABAAG standards for a toilet lock. Lockset will be satin brass finish. Lockset will be 3400 Series Lever by Hager Companies 1-800-255-3590.
 - 4.13.4.2 Lever handles inside and outside with the end of handles return to within 1/2" to 3/4" of door surface.
 - 4.13.4.3 Either handle operates latch unless outside handle is locked by inside push button.
 - 4.13.4.4 Push-button will automatically release when inside lever handle is turned or door is closed.
 - 4.13.4.5 Lockset will have an emergency slot on exterior so door can be unlocked from the outside with a screwdriver. Inside lever will always be active.
 - 4.13.5 Deadbolt - Mortised type, operated by key from outside only, keyed to existing or provided key. Deadbolt will be 3100 series by Hager Companies, 1-800-255-3590.

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications



4.13.6 Bumpers

4.13.6.1 Wall Bumpers will have a cast metal base, satin brass finish, convex gray rubber bumper with a 2 3/8" diameter and 1" projection, suitable for installation on exterior of steel door. Wall bumpers will be #236W by Hager Companies, 1-800-255-2590

4.13.6.2 Floor Stops will be available as an option to be mounted or grouted in concrete entrance slab to limit the travel of door under windy conditions. Rubber bumper diameter to be 2" with a height of 3 1/2" and mounted using a 5/8" steel bolt. Floor stop will be 269T by Hager Companies, 1-800-255-2590.

4.13.7 Door and Wall Louvers

4.13.7.1 Door Louvers will consist of non-vision, two-piece, exterior door louver for mounting on each side of door. Fiberglass or nylon insect screen with a 18-14 mesh installed in an aluminum frame between louvers. Frames will have one coat of factory applied baked on primer and sprayed with finish coat to match door. Door louvers will be Model 700A by Air Louvers Inc. 1-323-726-8814.

4.13.8 Door Sill Seal will be provided at the bottom of door and will be extruded aluminum channel with one-inch legs on each face of door with vinyl insert on bottom. Door Sill Seal will be #782S by Hager Companies, 1-800-255-3590.

4.13.9 Double Coat Hook - As an option a double coat hook of stainless construction with a satin finish and nail in anchor may be installed. Upper hook shall extend at least 2 1/2" from wall and lower hook extend 1 1/4" from wall. Mounting height will be a maximum of 48" from floor to center of coat hook. Double coat hook will be #895 by Tubular Specialties, Inc. 1-800-472-2227.

4.14 Standard Vault Cleanout - The vault cleanout will be located on the back of the toilet and be 12" Polylok plastic risers embedded into the sidewall of the vault at a 60 degree angle to the center of the vault. Risers will extend to 4" above grade and be sealed with a plastic lid. Risers and lid are water and air tight and lock together with stainless steel screws.

Clovermist Plus and Double Vault Toilet cleanouts will be located on the back of the toilet and will be a raised steel frame 21" by 34". The door will be 1/4" Diamond plate steel and will be hinged at the back with a locking hasp that accepts a standard owner supplied padlock. The vault cleanout door and frame will be factory Powder coated in Teakwood brown and include a continuous rubber gasket around the perimeter which will provide an air tight seal.

4.15 Vault Vent Pipe shall be polyethylene plastic pipe, 12" DR21, PE 3608 high density, black color, UV stabilized HDPE pipe manufactured by WL Plastics, 307-682-5554.

4.16 Vault/Liner

4.16.1 Standard Vault configuration will include a precast concrete vault with a minimum wall thickness of 3". The inside of the vault will be allowed to cure for seven days and then be coated with two coats of Conseal CS-55 applied with a paint roller. The vault/liner will have a 5-year warranty against leakage.

4.16.2 An optional double walled vault will be available at extra cost. The optional vault will consist of the standard concrete vault with a one piece molded plastic liner placed inside the concrete tank. The Vault Liner shall consist of a one-piece molded .22" thick LDPE plastic liner by Snyder Industries, Inc. The LDPE plastic liner will be warranted against leaks for a period of 7 years.

5.0 MANUFACTURE

5.1 Concrete Forms

5.1.1 Steel forms shall be sufficiently rigid to prevent distortion due to pressure of the concrete during placement, vibrating and curing of concrete.

5.1.2 Form ties will not be used in any concrete

5.1.3 Forms will be constructed to allow the interior surface of walls, ceiling and vault to have a steel form finish. Upper surface of the roof slab will have a steel-trowel finish standard with other optional textures by means of form liner.

5.1.4 Form liner patterns shall be continuous pattern match.

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications



5.2 Reinforcement

5.2.1 All reinforcing steel and wire mesh will be put in place and supported in final position prior to placement of concrete.

5.3 Concrete

5.3.1 Placement - Concrete will be poured in layers not more than 24" deep. Vibrators or tampers will not be used to move concrete.

5.3.2 Vibrating -

5.3.2.1 The concrete will be consolidated with suitable mechanical vibrators operating within the concrete or attached to the steel forms.

5.3.2.2 Vibration will be done at all points to sufficiently accomplish compaction and not prolonged to a point where segregation would occur.

5.4 Construction and Execution

5.4.1 The walls will be a minimum of 4" thick and the floors 5" unless otherwise specified on the drawings.

5.4.2 Standard exterior surfaces of all colored concrete components shall have exposed aggregate finish. The exposed aggregate finish will be accomplished by sandblasting, brushing, or other approved methods that will remove 1/8" to 1/4" of cement mortar from surface of concrete. The Manufacturer will have available a 12" x 12" colored sample with the exposed aggregate finish for approval. Other optional exterior finishes will be available.

5.4.3 Any exterior exposed aggregate finish will be cleaned, allowed to dry and a concrete sealer will be applied as recommended by the manufacturer.

5.4.4 The four sections of the concrete building will be joined at the seam with epoxy concrete adhesive and/or four weld plates, two on top and two on bottom. Excess epoxy will be removed flush with concrete surfaces.

5.4.5 The floor slab will be fabricated with a 1" to 2" inch high raised concrete cove around the perimeter except in the door opening.

5.4.6 Interior vertical wall surfaces will have all depressions and small rock pockets filled with cement mortar while concrete is still green and within one day of form removal.

5.4.7 Patching of holes, chips, exposed reinforcement, and other defects on the exterior of the building will be done with a Portland cement-based patching material with the color, finish and texture of the patched surface matching the surrounding concrete.

5.4.8 Signs will be installed on building as shown on drawings per ADA-ABA guidelines.

5.4.9 All hardware will be installed in accordance with manufacturer's instructions after finish paint work is completed.

5.4.10 Spring hinges will be adjusted after the building is installed to meet the following criteria:

5.4.10.1 Maximum force for pushing or pulling open the door shall be five pounds.

5.4.10.2 The door shall take at least three seconds to move from an open position of 70 degrees to a point three inches from the latch, measured to the leading edge of the door.

5.4.11 Wall bumpers will be installed on outside of steel door as shown on drawings to contact concrete wall near edge of the building.

5.4.12 Glazing will be installed as shown on drawings with glazing strips on the exterior side of the glazing, secured a maximum of ten inches on center with corrosion resistant Phillips metal screws.

5.4.13 Tan or grey concrete enamel on the floor shall extend around the cove at the junction of the wall and floor. Line between the tan or grey floor enamel and white wall enamel shall be straight and parallel to the floor.

5.4.14 Concrete surfaces will be allowed to adequately cure and surfaces will be prepared for application of paints as recommended by the paint manufacturer.

5.4.15 Interior and exterior joints between concrete and steel frames of doors will be caulked and joints will be smoothed with a concave surface tool.

BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Specifications

6.0 INSTALLATION

6.1 Scope of Work:

- 6.1.1 Work specified under this Section includes, unless otherwise noted, site location, excavation, backfill and placement of precast concrete vault toilet.

6.2 Materials

- 6.2.1 Bedding material to be sand or $3/8$ " minus crushed or screened aggregate.

6.3 Location and Access to the Site:

- 6.3.1 It is the responsibility of the customer to locate the vault toilet in area that provides safe and reasonable access for trucks and equipment.
- 6.3.2 The area must be free of overhead or underground obstructions. Customer is responsible for all permits and locates.
- 6.3.3 Care must be taken to not place excavated material in the area where the crane or truck may be positioned.
- 6.3.4 Verify that bridges/culverts en-route to the site are rated for HS-20 loading.
- 6.3.5 Deliveries may be delayed if road conditions are hazardous or unsuitable for normal trucks and trailers.
- 6.3.6 Trucks must be able to reach the site under their own power.

6.4 Excavation and Elevation

- 6.4.1 Comply with all applicable OSHA Standards for excavation.
- 6.4.2 The Boom Clovermist STANDARD vault toilet requires a excavated hole that is 8ft wide and 8ft long as measured at the bottom. Depth should be 48 inches below finished grade. The Boom Clovermist PLUS and DOUBLE vault toilets requires a excavated hole that is 15' long by 9' wide and the depth shall be 52.5" below finished grade.
- 6.4.3 Finish floor elevation will be 4 inches above natural grade measured at the front (entrance) of the exterior slab unless otherwise approved by the customer. The customer may specify a finish floor elevation for buildings at some sites. The contractor will install buildings at these sites with the floor elevation within ± 0.05 feet of the specified floor elevation. It is very important that the installation provides drainage away from the structure.

6.5 Bedding and Compaction

- 6.5.1 Compact the natural ground at the bottom of the vault excavation with a whacker-type mechanical compactor or equivalent approved by the manufacturer.
- 6.5.2 Install sand or aggregate bedding material for leveling course. Compact leveling course so there will be no high spots in the middle of the vault bottom.
- 6.5.3 Set vault in place. Backfill around the structure. Use excavation material for backfill except that rocks larger than 6" in maximum dimensions shall not be placed within 6" of the exterior vault walls.
- 6.5.4 Fill, adjacent to the building entry, will have excavated material placed in eight inch loose lifts and compacted with a whacker-type mechanical compactor or equivalent.

6.6 Finish Grading

- 6.6.1 Spread excess excavated material from the vault around structure. Intended final grade is flush with the top of the front slab. Allow for placement of topsoil to reach that grade. Grade back fill away from structure at maximum slope of five (5) percent unless otherwise approved by the customer.
- 6.6.2 Spread stockpiled topsoil as final layer after rough grading is completed.



BOOM

Concrete, Inc.

Boom Concrete, Inc.
220 Girard Avenue
PO Box 437
Newell, SD 57760

Toll Free: 800-464-2600
Telephone: 605-456-2600
Fax: 605-456-6060
Website: www.boomcon.com
Email: lfox@boomcon.com

January 1, 2016

Clovermist Vault Toilet Warranty



7.0 WARRANTY

7.1 Boom Concrete, Inc. precast vault toilets when installed in accordance with the manufacturer's instructions are warranted against defective materials and/or workmanship for a period of 20 years from date of delivery. All non-concrete components such as windows, vents, vault toilet risers, grab bars, toilet paper dispensers, doors, locksets, dead bolts, door sweep, door stops, coat hooks, signs and vault vent pipes will carry a 1 year warranty from date of delivery. As an option the double walled vault with plastic liner will include a water tightness warranty for a period of 7 years from date of purchase.

- 7.1.1 Should a defect appear within the warranty period, Boom Concrete, Inc. will, at its discretion, repair or replace the precast concrete parts that have deteriorated due to such defects in material and/or workmanship provided that Boom Concrete, Inc. is first given the opportunity to inspect such defects. It is specifically understood that Boom Concrete's obligation is for credit, repair or replacement only, and does not include shipping, handling or installation.
- 7.1.2 Boom Concrete, Inc. liability is limited to the value of the precast vault toilet itself and specifically excludes the cost of installation and/or removal and consequential damages.
- 7.1.3 Failure to comply with Boom Concrete, Inc. installation procedures and general notes will void warranty. Boom Concrete, Inc. assumes no liability in cases of improper installation or misuse.

8.0 DISCLAIMER OF OTHER WARRANTIES

8.1 The warranty set forth above is in lieu of all other warranties, express or implied. All other warranties are hereby disclaimed. Boom Concrete, Inc. makes no other warranty of merchantability of or fitness for a particular purpose or use.

9.0 LIMITATION OF REMEDIES

9.1 In the event of any breach of any obligation hereunder; breach of any warranty regarding the goods or any negligent act or omission of any party, the parties shall otherwise have all rights and remedies available at law; however, in no event shall Boom Concrete, Inc. be subject to or liable for any incidental or consequential damages.

10.0 RETURN POLICY

10.1 Boom Concrete Clovermist Vault Toilets are pre-fabricated structures. During the process of production, delivery and installation Boom Concrete works with the customer to ensure the product meets their requirements and address any issues. Based on the size and weight of the buildings there are no provisions for return once the customer accepts delivery.